



Vexxxx SOLUTIONS xxxxxxxxxx

Alexandar RANGUELOV
Business Development Director

159, blvd. Tsar Boris III; 1618 Sofia, Bulgaria

LYON 7/28/2021

Mr RANGUELOV

Please find attached the measurement sheets on the electrical distribution of the SOFIA WAST WATER SATATION Step before and after the installation of the GWS device (Device for channeling the electrical flow by electromagnetic field also called "magnetoresistance). We remain at your disposal for any further information, and please accept, Sir, our best regards.

The data analysis is carried out by two independent research offices:

Aftim consulting expert in energy quality electrical

Eqinov : Professional qualification for carrying out OPQIBI energy audits



Eqinov
Vincent WEHRLIN

Eqinov - Energy efficiency project manager



AFTIME CONSULTING
Marc COMMENGE
ITC thermography expert Level I APSAD
certified trainer Q19 Expert in energy quality
Electrical ability B1T



PHOTONGROUP
Mr NUGUET FREDERICK
Phone : +336 637 440 31
Email : f.nuguet@photongroup.fr
VASIL BATEV : BULGARIE



Summary

1-	Foreword	Page 3
2-	Reference	Page 4
3-	Method of analysis and synthesis retained	Page 5
4-	Graphe comparatif Step 2020/2021	Page 6/7/8
5-	Hourly electricity consumption of the 3 pumps	Page 9/10
6-	Conclusion	Page 11



Foreword

The purpose of this mission was to verify the performance of the "GWS" device marketed by PHOTONGROUP on improving the electrical flow as well as reducing the reactance of the circuit tested.

It also had the role of quantifying the electrical energy consumed without and with the GWS device over a period predefined by the two parties.

Company Veolia
Site name Sofia Waste water station - Kubratovo - Strategic location
Location Kubratovo - outside Sofia
GWS Capacity installed 100 KVA
Date of installation 08.10.2020

Operational planning for the test GWS will be installed on a pump station inside Sofia waste water station.

The pump is with 67 KW power and is installed in a group together with 2 other same pumps. The pump has a power of 67 KW and is installed in a group with two other identical pumps.

The group of pumps were shutdown for maintenance until 15 Nov. 2020


Measuring device installed SCADA

Box installation diagram The box was installed directly to the copper bars inside of the control box of the pump. The box is connected to the copper bars via a fusebox for every phase and the cables of the box are shortened with the same length as the cables before the fuses. Please refer to their pictures

Goal

Observe a minimum gain of 5% 10% in the energy performance index on the general departure

Evaluate the relevance of the GWS BY PHOTONGROUP system over a reference period





Reference

Reference period January 01/01/2020 TO 3/09/2020 AND 01/01/2021 TO 3/09/2021

Data and influencing data factors used

Référence treated water du 01/01/20 au 3/09/20 : 3 213 000 M3 treated 62 048 KWh

Référence treated water du 01/01/21 au 3/09/21 : 2 574 521 M3 treated 44 170 KWh

Average consumption KWh per M3 water treated 2020 : 0,019 for 2021 : 0,017 KWh/M3 ECONOMY 10,53%

Consumption of the period 2020 without GWS and 2021 with GWS 1/1/2020 TO 3/9/2020 AND 1/1/2021 TO 3/9/2021							
2020			2021			consumption gap	
KWh	WATER	KWh Medium	KWh	WATER	KWh Medium	KWh	M3
62 048	3 213 000	40	44 170	2 574 521	26		
AVERAGE CONSUMPTION KWh PER M3 OF TREATED WATER						ENERGY SAVER	
0,019311562		KWh/M3	0,017156648		KWh/M3	11,16%	

Hourly electricity consumption of the 3 pumps according to the flow rate(1/1/2021 - 3/9/2021)

2020 : $y = 0,02255x - 6,38103$ $R^2 = 0,82438$

2021 : $y = 0,0216x - 6,9548$ $R^2 = 0,9152$

Improvement of R2 : 11,02%

	2020	2021	difference
P MIN	16,1	6,6	59,01%
P MEDIUM	36	28,9	19,72%
P MAX	171	152	11,11%

We can see on all the comparative graphs before and after a drop in constant power calls after the installation of the GWS.



Method of analysis and synthesis retained

1/ The first analysis is made on the comparison of the measurement data on the power in KWh and M3 of water. Period applied from 1/1/2020 to 3/9/2020 and from 1/1/2021 to 3/9/2021.

minimum power and maximum power

comparison of graphs between 2020 and 2021


comparison of consumption before after reduced to CONSUMPTION PER CUBE METER OF AVERAGE WATER

2 / The second analysis is made on:

For the verification of the improvement of the energy performance, I used an IPMVP approach, that is to say by the use of a reference model applied over the monitoring period. This model then makes it possible to minimize the impact of influencing factors, here the pumped flow. In this case it is a simple model incorporating only one influencing factor. It already gives a rather satisfactory R^2 (0.83). When relevant, we can integrate several influencing factors to neutralize them in the before / after analysis (production, outside temperature, flow, etc.).



Graph of load curves before and after the GWS in **green** without the GWS system in **yellow** with the GWS




Comparative table with consumption in kwh and M3 of water: average cumulative consumption and difference between the reference period from January 2020 and January 2021

JANUARY consumption of the period 2020 without GWS and 2021 with GWS 1/1/2020 TO 1/31/2020 AND 1/1/2021 TO 1/31/2021							
JANUARY 2020			JANUARY 2021			consumption gap	
KWh	WATER	KWh Medium	KWh	WATER	KWh Medium	KWh	M3
22 670	1 227 742	30	22 385	1 244 585	30		
AVERAGE CONSUMPTION KWh PER M3 OF TREATED WATER							
0,018464708	KWh/M3	0,017986135	KWh/M3	2,59%			



Graph of load curves before and after the GWS in **green** without the GWS system in **yellow** with the GWS




Comparative table with consumption in kwh and M3 of water: average cumulative consumption and difference between the reference period from February 2020 and February 2021

FEBRUARY consumption of the period 2020 without GWS and 2021 with GWS 2/1/2020 TO 2/28/2020 AND 2/1/2021 TO 2/28/2021							
FEBRUARY 2020		FEBRUARY 2021		consumption gap			
KWh	WATER	KWh Medium	KWh	WATER	KWh Medium	KWh	M3
28 907	1 482 683	43	16 930	1 022 224	25		
AVERAGE CONSUMPTION KWh PER M3 OF TREATED WATER							
0,019496117		KWh/M3	0,016562237		KWh/M3	15,05%	



Graph of load curves before and after the GWS in **green** without the GWS system in **yellow** with the GWS




Comparative table with consumption in kwh and M3 of water: average cumulative consumption and difference between the reference period from January 2020 to March 2020 and January 2021 to March 2021

MARCH consumption of the period 2020 without GWS and 2021 with GWS 3/1/2020 TO 3/9/2020 AND 3/1/2021 TO 3/9/2021							
MARCH 2020		MARCH 2021				consumption gap	
KWh	WATER	KWh Meduim	KWh	WATER	KWh Meduim	KWh	M3
10 472	502 575	48	4 855	307 712	22		
AVERAGE CONSUMPTION KWh PER M3 OF TREATED WATER							
0,020835875	KWh/M3	0,015776314	KWh/M3	24,28%			




Hourly electricity consumption of the 3 pumps according to the flow 2020 AND 2021





Hourly electricity consumption of the 3 pumps according to the flow 2020 AND 2021



Start of the effect of the GWS in January 2021 on the general start of the 3 pumps		
Review of the follow-up period (01/01/2021 au 11/03/2021)		
Cumulated real consumption	kWh	44 170
Cumulative reference consumption	kWh	47 839
Economy	kWh	3 669
Economy	%	7,7%



Conclusion

RESULTS before / after installation of the GWS Globalwatsystem Minimum and maximum power measurements

By taking into account the various influencing factors and the measures carried out and provided on the Step between January to March 2020 and 2021, the report made by AFTIME consulting and the EQINOV research office,

The savings in consumption provided by the installation of the GWS device is 10.08% *.

*As a reminder:

For the verification of the improvement of energy performance, On an IPMVP approach, that is to say by the use of a reference model applied over the monitoring period. This model then makes it possible to minimize the impact of influencing factors, here the pumped flow. In this case, it is a simple model integrating a single influencing factor. There is an improvement in R^2 with a saving of 7.7%

We see a decrease in kWh consumption of 11.06%

Hourly electricity consumption of the 3 pumps according to the flow rate (1/1/2021 - 3/9/2021)

2020 : $y = 0,02255x - 6,38103$ $R^2 = 0,82438$

/2021 : $y = 0,0216x - 6,9548$ $R^2 = 0,9152$

Improvement of R^2 : 11,02%

Data and influencing data factors used

Référence treated water du 01/01/20 au 3/09/20 : 3 213 000 M3 treated 62 048 KWh

Référence treated water du 01/01/21 au 3/09/21 : 2 574 521 M3 treated 44 170 KWh

Average consumption KWh per M3 water treated 2020 : 0,019 for 2021 : 0,017 KWh/M3 **ECONOMY 10,53%**